



**City of Mason
Public Notice**

On February 20, 2018, due to a large amount of rainfall combined with higher than normal temperatures leading to large amounts of snow melt the City of Mason's Waste Water Treatment Plant experienced flooding conditions. Due to high flows, combined with a primary tank failure, a limited amount of partially treated wastewater overflowed the primary tank. It is estimated that approximately 5,000 gallons of partially treated wastewater was bypassed onto the ground.

Sarah Jarvis
Mason City Clerk